



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1050031

Master Contract: 200895

Project: 1940182

Date Issued: 2007/07/30

Issued to:

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: S. Ahn

Authorized by: Nick Alfano, Operations Manager

PRODUCTS

CLASS 4211 81 - MOTORS AND GENERATORS - Certified to US Standards

CLASS 4211 01 - MOTORS AND GENERATORS

Three Phase Squirrel Cage Induction Motor, Types BJHE, TEAMHE, 1 to 400 hp, 208-230/460V, 460V or 575V, 60 Hz, Class F insulated, 40 C amb., horizontal or vertical, flange with/without foot mounting. Enclosure TEFC. Continuous duty, SF 1.15 max. NEMA frames 143T to 587T (includes TS, TC, TD), 2, 4 and 6 pole, NEMA series A or B.

Three phase Squirrel Cage Induction Motor, Type BJHE, 208-230/460V, 460V or 575V, 60Hz, Class F insulation, 40C Amb, Horizontal or Vertical, flange with/without foot mounting, Enclosure TEFC, Continuous duty

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.