



09

## EC DECLARATION OF CONFORMITY

We,

FACTS Engineering, LLC.  
Rick Walker  
8049 Photonics Drive  
New Port Richey, FL

Declare under our sole responsibility that our Signal Conditioners (intended for building-in to open PLC Systems) to which this declaration relates is in conformity with the following:

**Low Voltage Directive 2014/35/EU of 20 April 2016**

**Electromagnetic Compatibility Directive 2014/30/EU of 26 February 2014**

Per the provisions of the following standard.

EN61131-2: 2007 (Programmable Controllers, Third Edition/2007-07) Zone B

**RoHS Directive 2011/65/EU of 8 June 2011 and amendment (EU) 2015/863**

More specifically, the following substances are restricted in the production of above products according to Directive limits:

Cadmium (Cd)	100 ppm
Hexavalent chromium (Cr <sup>6+</sup> )	1,000 ppm
Lead (Pb)	1,000 ppm
Mercury (Hg)	1,000 ppm
Polybrominated biphenyls (PBB's)	1,000 ppm
Polybrominated diphenyl ethers (PBDE's)	1,000 ppm
Bis(2-Ethylhexyl) phthalate (DEHP)	max 0.1%
Benzyl butyl phthalate (BBP)	max 0.1%
Dibutyl phthalate (DBP)	max 0.1%
Diisobutyl phthalate (DIBP)	max 0.1%

**REACH Directive EC No 1907/2006 of 18 December 2006**

The total amounts of the substances present are less than 0.1% weight X weight.

\_\_\_\_\_  
Rick Walker, Vice President

\_\_\_\_\_  
Date

The following modules are covered:

FC-33, FC-11, FC-T1, FC-R1, FC-3RLY2, FC-3RLY4, FC-ISO-C, FC-ISO-D, FC-B34, FC-35B, FC-P3

Additional Information:

It is required that all PLC equipment must be housed in a protective steel enclosure, which limits access to operators by lock and power breaker and that all cables exit enclosure, do so through metallic conduits.