

TÜV SÜD
ZERTIFIKAT ♦ CERTIFICATE ♦ 認證書 ♦ CERTIFICADO ♦ CERTIFICAT



Product Service

Attestation of Conformity

No. N8A 052840 0048 Rev. 00

Holder of Certificate: **Samwon Act Co., Ltd.**
28, Daedong-ro, Sasang-gu
Busan 47035
REPUBLIC OF KOREA

Product: **Terminal block
(Common Interface Terminal)**

Model(s): **XTB-COM20, XTB-COM20B, XTB-COM20C,
XTB-COM40, XTB-COM40B, XTB-COM40C**

Parameters:	Rated input voltage:	125 V a.c. / 24 V d.c.
	Rated input current:	10 A
	Overvoltage category:	II
	Pollution degree:	2
	Degree of protection against ingress of liquids:	IP20

Tested according to: EN 61131-2:2007

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSZ09319418

Date, 2018-09-12

(Harry Kwon)

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

CERTIFICATE OF COMPLIANCE

Certificate Number 2018-10-29-E501983
Report Reference E501983-D1000-1/A0/C0-UL
Issue Date 2018-10-29

Issued to: SAMWON ACT CO LTD
Applicant Company: 28 Daedong-ro Sasang-gu
Busan, 47035 REPUBLIC OF KOREA

Listed Company: Same as Applicant

This is to certify that representative samples of Industrial Control Equipment
XTB Series, Models XTB-20H, XTB-26H, XTB-34H, XTB-40H, XTB-50H, XTB-50B.
XTB-COM Series, Models XTB-COM20, XTB-COM20B, XTB-COM20C, XTB-COM40, XTB-COM40B, XTB-COM40C.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 61010-1 SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL, AND LABORATORY USE - PART 1: GENERAL REQUIREMENTS- Edition 3 - Revision Date 2016-04-29
CSA C22.2 NO. 61010-1-12 SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL, AND LABORATORY USE - PART 1: GENERAL REQUIREMENTS - THIRD EDITION; APRIL 2016

Additional Standards: UL 61010-2-201 STANDARD FOR SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL, AND LABORATORY USE - PART 2-201: PARTICULAR REQUIREMENTS FOR CONTROL EQUIPMENT - Edition 2 - Revision Date 2018-05-14
CSA C22.2 NO. 61010-2-201:14 SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL, AND LABORATORY USE - PART 2-201: PARTICULAR REQUIREMENTS FOR CONTROL EQUIPMENT- Edition 2 - Issue Date FEBRUARY 2018


Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services, UL LLC
Joseph Hosey, General Manager, Director of Sales – Canada, UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative www.ul.com/contactus



Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information.

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services, UL LLC
Joseph Hosey, General Manager, Director of Sales – Canada, UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative www.ul.com/contactus

