

Testing laboratory
rue de Westhouse
B.P. 10
67230 BENFELD
Tel. (33) 03 88 57 41 41
Fax (33) 03 88 57 42 20

ATTESTATION OF CONFORMITY CE No AC 11220 CPR

Following specifications:
EN 60947-3 (2009)

TESTED MATERIAL

Designation : Switch-disconnector fitted with their original accessories

Type : SIRCO UL

Rating : 100 A ; 200A ; 400A ; 600A ; 800A ; 1200A

References : 27003011; 27004011; 27003021; 27004021; 27003041; 27004041;
27003060; 27004060; 27003080; 27004080; 27003120; 27004120

Manufacturer : SOCOMEC S.A. 67230 BENFELD FRANCE

Rated characteristics:

The above mentioned materials,

-subject to installation, maintenance and use according to its intended purpose, to its regulations, to the standards in force and to the manufacturer's instructions and rules-

Satisfy to the European Low voltage directive n° **2006/95/CE** dated **12.12.06**,

and to the European EMC directive n° **2004/108/CE** dated **15.12.04**.

Year of the CE marking apposition: **2010 (100A) ; 2009 (200A and 400A) ; 1998 (600A to 1200A)**

Enclosures : /

Date: February, 24th 2012
The Writer



Elodie WAGNER



**Test, Standard and Certification
Manager**



Dominique MARBACH