**(**E 10

### EC DECLARATION OF CONFORMITY

We,

FACTS Engineering, LLC. Rick Walker 8049 Photonics Drive New Port Richey, FL

Declare under our sole responsibility that our CLICK Analog Modules (intended for building-in to open PLC Systems) to which this declaration relates is in conformity with the following:

# Low Voltage Directive 2014/35/EU of 20 April 2016 Electromagnetic Compatibility Directive 2014/30/EU of 26 February 2014

Per the provisions of the following standard. EN61131-2: 2007 (Programmable Controllers, Third Edition/2007-07)

#### RoHS Directive 2011/65/EU of 8 June 2011 and amendment (EU) 2015/863

More specifically, the following substances are restricted in the production of above products according to Directive limits:

Cadmium (Cd)	100 ppm
Hexavalent chromium (Cr6+)	1,000 ppm
Lead (Pb)	1,000 ppm
Mercury (Hg)	1,000 ppm
Polybrominated biphenyls (PBB's)	1,000 ppm
Polybrominated diphenyl ethers (PBDE's)	1,000 ppm
Bis (2-Ethylhexyl) phthalate (DEHP)	max 0.1%
Benzyl butyl phthalate (BBP)	max 0.1%
Dibutyl phthalate (DBP)	max 0.1%
Diisobutyl phthalate (DIBP)	max 0.1%
to the second of	

#### REACH Directive EC No 1907/2006 of 18 December 2006

We are aware of the SVHC (substances of very high concern) of the REACH regulation. . This includes the 4 substances announced as the 26<sup>th</sup> Candidate on January 2022 and all items comply with the global standard.

The total amounts of the substances present are less than 0.1% weight X weight.



Rick Walker, Vice President

The following modules are covered:

C0-04AD-1, C0-04AD-2, C0-04DA-1, C0-04DA-2, C0-04RTD, C0-04THM, C0-4AD2DA-1, C0-4AD2DA-2

## Additional Requirements:

It is required that all PLC equipment must be housed in a protective steel enclosure, which limits access to operators by lock and power breaker and that all cables exit enclosure, do so through metallic conduit.